

ETA-Danmark A/S Göteborg Plads 1 DK-2150 Nordhavn Tel. +45 72 24 59 00 Internet <u>www.etadanmark.dk</u> Authorised and notified according to Article 29 of the Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011



# European Technical Assessment ETA-22/0711 of 2023/02/15

I General Part

Technical Assessment Body issuing the ETA and designated according to Article 29 of the Regulation (EU) No 305/2011: ETA-Danmark A/S

Trade name of the construction product:	FernoCryl
Product family to which the above construction product belongs:	<ul><li>Fire Stopping and Sealing Product:</li><li>Penetration Seals</li></ul>
Manufacturer:	Bloem Sealants BV Westvlietweg 69 NL-2495AA Den Haag Netherlands <u>www.bloemsealants.com</u>
Manufacturing plant:	A/003
This European Technical Assessment contains:	86 pages including 2 annexes which form an integral part of the document
This European Technical Assessment is issued in accordance with Regulation (EU) No 305/2011, on the basis of: This version replaces:	EAD 350454-00-1104 -

Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and should be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may be made, with the written consent of the issuing Technical Assessment Body. Any partial reproduction has to be identified as such.

#### Table of Contents

ι.	SPECIF	IC PARTS OF THE EUROPEAN TECHNICAL ASSESSMENT	4
1	Те	chnical description of the product	4
2		ecification of the intended uses of the product in accordance with the applicable European Assessment Document (Hereinafter EAD): E 0454-00-1104	
3	Pe	rformance of the product and references to the methods used for its assessment	7
4		SESSMENT AND VERIFICATION OF CONSTANCY OF PERFORMANCE (HEREINAFTER AVCP) SYSTEM APPLIED, WITH REFERENCE TO ITS LEC SE	
5	Те	chnical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD	8
ANN	EX A – R	esistance to Fire Classification – FernoCryl	9
A	.1	Rigid wall constructions according to 1.2.1 with wall thickness of minimum 150 mm	9
	A.1.1	Single side penetration seal with cables	9
	A.1.2	Double side penetration seal with cables	10
	A.1.3	Single side penetration seal with metallic (and composite) pipes	11
	A.1.4	Single side penetration seal with metallic (and composite) pipes	13
	A.1.5	Single side penetration seal with metallic pipes	15
	A.1.6	Double side penetration seal with metallic pipes	17
	A.1.7	Double side penetration seal with metallic pipes	19
	A.1.8	Double side penetration seal with metallic pipes with combustible insulation	21
	A.1.9	Double side penetration seal with plastic pipes	23
A	.2	Flexible and rigid wall constructions according to 2. 2) with wall thickness of minimum 75 mm	25
	A.2.1	Double side penetration seal with cables	
A	.3	Flexible and rigid wall constructions according to 2.2) with wall thickness of minimum 100 mm	29
	A.3.1	Double side penetration seal with cables	
	A.3.2	Double side penetration seal with metallic pipes	31
	A.3.3	Double side penetration seal with metallic pipes	
	A.3.4	Double side penetration seal with composite pipes	
	A.3.5	Double side penetration seal with metallic (and composite) pipes	41
	A.3.6	Double side penetration seal with plastic pipes	43
A	.4	Flexible and rigid wall constructions according to 2.2) with wall thickness of minimum 120 mm	
	A.4.1	Double side penetration seal with cables	45
A	.5	Timber wall constructions with wall thickness of minimum 100 mm	46
	A.5.1	Double side penetration seal with cables	46
	A.5.2	Double side penetration seal with cables and FernoTherm Coating	47
	A.5.3	Double side penetration seal with metallic pipes	48
	A.5.4	Double side penetration seal with metallic pipes	51
	A.5.5	Double side penetration seal with plastic pipes and composite pipes	54
A	.6	Rigid floor constructions according to 1.2.1 with floor thickness of minimum 150 mm	57
	A.6.1	Single side penetration seal with cables	57
	A.6.2	Single side penetration seal with cables	58
	A.6.3	Single side penetration seal with pipes	59
	A.6.4	Double side penetration seal with pipes	61
	A.6.5	Double side penetration seal with cables	63
	A.6.6	Single side penetration seal with metallic pipes	64
	A.6.7	Single side penetration seal with metallic pipes	68
	A.6.8	Single side penetration seal with composite pipes	70
	A.6.9	Double side penetration seal with metallic pipes	71
	A.6.10	Double side penetration seal with metallic pipes	72
	A.6.11	Double side penetration seal with metallic pipes	76
A	.7	Timber floor constructions with floor thickness of minimum 150 mm	78
	A.7.1	Double sided penetration seal with cables	78
	A.7.2	Double side penetration seal with metallic pipes	80
	A.7.3	Double side penetration seal with plastic pipes and composite pipes	83
ANN	EX B – Ai	r Permeability – FernoCryl	86

#### I. SPECIFIC PARTS OF THE EUROPEAN TECHNICAL ASSESSMENT

#### 1 <u>Technical description of the product</u>

- FernoCryl is a sealant used to form a penetration seal around metallic pipes, plastic pipes, composite pipes, combustible cable conduits and electrical cables to reinstate the fire resistance performance of wall and floor constructions, where they have been provided with apertures for the penetration of services.
- 2) The FernoCryl is supplied in liquid form contained within 310 ml cartridges and 600 ml foil packs. The sealant is gunned into the aperture in the separating element/elements and around the service or services, to a specified depth utilising mineral fibre insulation backing material.
- 3) FernoCryl contains no carcinogenic substances or mutagenic substances, flame retardants or antimicrobiological agents.
- 4) The applicant has submitted a written declaration that FernoCryl does not contain substances which have to be classified as dangerous according to Directive 67/548/EEC and Regulation (EC) No 1272/2008 and listed in the "Indicative list on dangerous substances" of the EGDS taking into account the installation conditions of the construction product and the release scenarios resulting from there. An emission report has also been provided.

In addition to the specific clauses relating to dangerous substances contained in this European technical Assessment, there may be other requirements applicable to the products falling within its scope (e.g. transposed European legislation and national laws, regulations and administrative provisions). In order to meet the provisions of the Construction Products Regulation, these requirements need also to be complied with, when and where they apply.

5) The use category of FernoCryl in relation to BWR 3 (Hygiene, health and environment) is IA1, S/W2

#### 2 <u>Specification of the intended uses of the product in accordance with the applicable European Assessment</u> <u>Document (Hereinafter EAD): EAD 350454-00-1104</u>

Detailed information and data is given in Annex A.

- 1) The intended use of system FernoCryl is to reinstate the fire resistance performance of flexible wall constructions, rigid wall constructions and rigid floor constructions where they are penetrated by various metal pipe services with and without combustible insulation, plastic pipes, combustible cable conduits, composite pipes and electrical cables.
- 2) The specific elements of construction that the system FernoCryl may be used to provide a penetration seal in, are as follows:
  - a. Flexible walls: The wall must have a minimum thickness of 75 mm and comprise steel studs or timber studs\* lined on both faces with minimum 1 layer of 12.5 mm thick boards.
    b. Timber walls: The wall must have a minimum thickness of 100 mm and comprise solid wood or cross-laminated timber.
  - c. Rigid walls: The wall must have a minimum thickness of 75 mm and comprise concrete, aerated concrete or masonry, with a minimum density of 650 kg/m<sup>3</sup>.
  - d. Rigid floors: The floor must have a minimum thickness of 150 mm and comprise aerated concrete or concrete with a minimum density of 650 kg/m<sup>3</sup>.
  - e. Timber floors: The floor must have a minimum thickness of 150 mm and comprise solid wood or cross-laminated timber.

\* no part of the penetration seal may be closer than 100 mm to a stud, the cavity must be closed between the penetration seal and the stud, and minimum 100 mm of insulation of class A1 or A2 according to EN 13501-1 must be provided within the cavity between the penetration seal and the stud.

The supporting construction must be classified in accordance with EN 13501-2 for the required fire resistance period.

Bloem Sealants BV Fire Protection Systems which involve services penetrating both sides of a flexible wall may also be used in the situation where the services penetrates one side of the wall only and the remaining side of the wall is not penetrated at the same point (i.e. the services continues on the inside of the wall). All fire integrity and thermal insulation ratings for such single-sided penetrations remain the same as for the equivalent double-sided penetration.

- 3) The system FernoCryl may be used to provide a penetration seal with specific single insulated metal pipes, uninsulated metal pipes, plastic pipes, combustible cable conduits, composite pipes and with specific electrical cables, single or in a bundle (for details see Annex A).
- 4) Apertures in the separating element shall be maximum Ø 504 mm, 300 x 300 mm or 100 x 1000 mm. The annular space/gap around the services shall be infilled with FernoCryl sealant and in some cases a mineral fibre insulation backing material. Blank seals up to 300 x 300 mm are permitted. For full details, see Annex A.
- 5) Pipes shall be supported at maximum 350 mm away from both faces of the wall constructions and from the upper face of floor constructions.

Page 6 of 86 of European Technical Assessment ETA-22/0711 issued on 2023-02-15

- 6) Where a backing material is described in Annex A, this can be replaced with FernoCryl if the total seal depth is the same or greater.
- 7) Where single sided top face seals are described in Annex A, these can also be used in composite floors if the thickness of the concrete where the seal is placed is the same or greater than the required depth of the fire seal.
- 8) Where PP pipes are mentioned in Annex A, this includes PP-MV, PP-H, PP-R and similar if the pipe is according to EN 1451-1 or DIN 8077/8078. Where PE pipes are mentioned, this includes PE-LD, PE-MD, PE-HD, PE-X and similar according to EN 1519-1, EN 12201-2 or EN 12666-1.
- 9) The provisions made in this European Technical Approval are based on an assumed working life of the FernoCryl of 30 years, provided that the conditions laid down in sections 4.2/5.1/5.2 for the packaging/transport/storage/installation/use/repair are met. The indications given on the working life cannot be interpreted as a guarantee given by the producer or the Technical Assessment Body but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.
- 10) Type Z<sub>2</sub>: Intended for uses in internal conditions with humidity lower than 85 % RH excluding temperatures below 0°C, without exposure to rain or UV.

# Page 7 of 86 of European Technical Assessment ETA-22/0711 issued on 2023-02-15

# 3 <u>Performance of the product and references to the methods used for its assessment</u>

Product-type: Sealant	Intended use: Penetration Seal	
Essential characteristic	Product Performance	
BWR 2 Safety	in case of fire	
Reaction to fire	Class B-s1, d0	
Resistance to fire	Annex A	
BWR 3 Hygiene, heal	th and environment	
Air permeability	Annex B	
Water permeability	No performance assessed	
Content, emission and/or release of dangerous substances	Use categories: IA1, S/W2 Declaration of manufacturer	
BWR 4 Safety in use		
Mechanical resistance and stability	No performance assessed	
Resistance to impact/movement	No performance assessed	
Adhesion	No performance assessed	
Durability	Z <sub>2</sub>	
BWR 5 Protectio	n against noise	
Airborne sound insulation	No performance assessed	
BWR 6 Energy econom	ny and heat retention	
Thermal properties	No performance assessed	
Water vapour permeability	No performance assessed	

#### 4 ASSESSMENT AND VERIFICATION OF CONSTANCY OF PERFORMANCE (HEREINAFTER AVCP) SYSTEM APPLIED, WITH REFERENCE TO ITS LEGAL BASE

According to the decision 1999/454/EC – Commission Decision of date 22nd June 1999 on the procedure for attesting the conformity of construction products pursuant to Article 20(2) of Council Directive 89/106/EEC as regards fire stopping, fire sealing and fire protective products, published in the Official Journal of the European Union (OJEU) L178/52 of 14/07/1999, (see https://eur-lex.europa.eu/oj/direct-access.html) of the European Commission<sup>1</sup>, as amended, the system(s) of assessment and verification of constancy of performance (see Annex V to Regulation (EU) No 305/2011) given in the following table(s) applies (apply).

Product(s)	Intended use(s)	Level(s) or class(es)	System(s)
Fire stopping and Fire Sealing Products	For fire compartmentation and/or fire protection or fire performance	Any	1

## 5 <u>Technical details necessary for the implementation of the AVCP system, as provided for in the applicable</u> <u>EAD</u>

Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited at ETA-Danmark A/S prior to CE marking

Issued in Copenhagen on 2023-02-15 by

Bruun Thomas

Managing Director, ETA-Danmark

<sup>&</sup>lt;sup>1</sup> Official Journal of the European Communities L178/52 of 14/7/1999

# ANNEX A – Resistance to Fire Classification – FernoCryl

# A.1 Rigid wall constructions according to 1.2.1 with wall thickness of minimum 150 mm

# A.1.1 Single side penetration seal with cables



## A.1.1.1

Services	Sealant	Backing	Maximum seal	Classification
	depth		size	
		48 mm deep		
Single electrical cables up to 21		Bloem		
Single electrical cables up to 21 mm Ø	25 mm	Mineral	87 mm Ø	E 240, El 90
nin Ø		Fiber Bio		
		Wool		
Blank seals		48 mm		
Electric cables up to 21 mm		Bloem	300 x 300 mm	E 240, EI 60
diameter, single.	25 mm	Mineral		
Blank seals	25 mm	Fiber Bio	25 v 25 mm / 26	
Electric cables up to 21 mm		Wool	35 x 35 mm / 36 mm Ø	E 240, El 120
diameter, single.		insulation	un p	

## A.1.2 Double side penetration seal with cables



## A.1.2.1

Services	Sealant depth	Backing (minimum)	Insulation	Classification
Blank seals				EI 240
Electric cables up to 21 mm diameter, single or in a bundle.	15 mm	25 mm Stone wool		E 240, El 120
Electric cables 22-80 mm diameter, single or in a bundle.		35 kg/m <sup>3</sup>		E 120, El 60
Blank seals		48 mm	None	EI 240
Electric cables up to 80 mm diameter, single or in a bundle.	25 mm	Bloem		E 240, El 60
Cables up to 21 mm diameter, single or in a bundle up to 100 mm diameter	25 11111	Fiber Bio Wool		EI 240

#### A.1.3 Single side penetration seal with metallic (and composite) pipes

**Penetration Seal:** LI (Local Interrupted) of minimum length stated below or CI (Continuous Interrupted) insulated metallic and composite pipes (single) fitted at any position within the aperture, with 15 mm deep FernoCryl to either side of the wall (or at any position between), backed with 20 mm deep minimum 40 kg/m<sup>3</sup> stone wool insulation\*.



#### A.1.3.1

Services	Seal width around pipe	Insulation (minimum)	Classification
Copper or steel pipe up to 54 mm diameter/0.9-14.2 mm wall	8-9 mm	1000 mm length 20 mm Stone wool	E 240 C/U, EI 180 C/U
Copper or steel pipe up to 12 mm diameter/0.9-5 mm wall	8 mm	insulation 80 kg/m <sup>3</sup>	EI 240 C/U
Alupex composite pipe 75 mm diameter/7.5 mm wall	30 mm	25 mm Bloem Mineral Fiber Bio Wool insulation, 600 mm long (min.)	EI 120 C/U

Services	Seal width	Insulation	Classification
Mild or stainless steel pipe	around pipe	(minimum)	
40 mm diameter/1.5-14.2 mm wall*		1000 mm length of 20 mm Stone wool insulation 80 kg/m <sup>3</sup>	EI 240 C/U
40 mm diameter/1.5-14.2 mm wall*			
50 mm diameter/1.7-14.2 mm wall*			
60 mm diameter/1.9-14.2 mm wall*			
75 mm diameter/2.2-14.2 mm wall*			
90 mm diameter/2.5-14.2 mm wall*			
100 mm diameter/2.7-14.2 mm wall*		1000 mm length of 30	
115 mm diameter/3-14.2 mm wall*		mm Stone wool insulation 80 kg/m <sup>3</sup>	E 180 C/U, EI 90 C/U
140 mm diameter/3.5-14.2 mm wall*	*		
165 mm diameter/ 3.9-14.2 mm wall*			
180 mm diameter/ 4.2-14.2 mm wall*			
200 mm diameter/ 4.6-14.2 mm wall*			
219 mm diameter/ 5.0-14.2 mm wall*			



#### A.1.4 Single side penetration seal with metallic (and composite) pipes

**Penetration Seal:** LI (Local Interrupted) of minimum length stated below or CI (Continuous Interrupted) insulated metallic and composite pipes (single) fitted at any position within the aperture, with 25 mm deep FernoCryl to either side of the wall (or at any position between), backed with 25 mm deep minimum 40 kg/m<sup>3</sup> stone wool insulation\*.



#### A.1.4.1

Services	Maximum Seal size	Insulation (minimum)	Classification
Copper or steel pipe up to 54 mm diameter/0.9-14.2 mm wall	300 x 300	1000 mm length 20 mm Stone wool insulation 80 kg/m <sup>3</sup>	
Alupex composite pipe 75 mm diameter/7.5 mm wall	mm	25 mm Bloem Mineral Fiber Bio Wool insulation, 600 mm long (min.)	E 240 C/U, EI 60 C/U

Page 14 of 86 of European Technical Assessment ETA-22/0711 issued on 2023-02-15

Services	Maximum seal	Insulation	Classification
Mild or stainless steel pipe	size	(minimum)	
40 mm diameter/1.5-14.2 mm wall*		1000 mm length of 20	
		mm Stone wool	
		insulation 80 kg/m <sup>3</sup>	
40 mm diameter/1.5-14.2 mm wall*			
50 mm diameter/1.7-14.2 mm wall*			
60 mm diameter/1.9-14.2 mm wall*			
75 mm diameter/2.2-14.2 mm wall*			
90 mm diameter/2.5-14.2 mm wall*			
100 mm diameter/2.7-14.2 mm wall*	300 x 300 mm	1000 mm length of 30	E 240 C/U, EI 60 C/U
115 mm diameter/3-14.2 mm wall*		mm Stone wool insulation 80 kg/m <sup>3</sup>	
140 mm diameter/3.5-14.2 mm wall*			
165 mm diameter/ 3.9-14.2 mm wall*			
180 mm diameter/ 4.2-14.2 mm wall*	k		
200 mm diameter/ 4.6-14.2 mm wall*			
219 mm diameter/ 5.0-14.2 mm wall*			

\* Typical pipe diameters shown, see below graph for intermediate sizes







A.1.5.1 Single side penetration seal with pipe
--

Services	Insulation	Classification
Mild or stainless steel pipe		
40 mm diameter/1-14.2 mm wall	20 mm thick stone, mineral wool min. 80 kg/m <sup>3</sup>	EI 240 C/U
40 mm diameter/1-14.2 mm wall*		
50 mm diameter/1.2-14.2 mm wall*		
60 mm diameter/1.4-14.2 mm wall*		
75 mm diameter/1.6-14.2 mm wall*		
90 mm diameter/1.9-14.2 mm wall*		
100 mm diameter/2.1-14.2 mm wall*		
115 mm diameter/2.4-14.2 mm wall*		
140 mm diameter/2.9-14.2 mm wall*	30-80 mm thick stone, mineral wool min. 80 kg/m <sup>3</sup>	EI 180 C/U
165 mm diameter/ 3.4-14.2 mm wall*		
180 mm diameter/ 3.6-14.2 mm wall*		
200 mm diameter/ 4.0-14.2 mm wall*		
219 mm diameter/ 4.3-14.2 mm wall*		
250 mm diameter/ 5.0-14.2 mm wall*		
300 mm diameter/ 5.9-14.2 mm wall*		
324 mm diameter/ 6.35-14.2 mm wall*		



#### A.1.6 Double side penetration seal with metallic pipes

**Penetration Seal:** 1000 mm (min.) LI (Local Interrupted) or CI (Continuous Interrupted) insulated metallic pipes (single) fitted at any position within the aperture, with 15 mm deep FernoCryl to both sides of the wall, backed with 20 or 30 mm deep minimum 40 kg/m<sup>3</sup> stone wool insulation.



# A.1.6.1

Services	Maximum seal	Insulation	Classification
Mild or stainless steel pipe	size	(minimum)	
40 mm diameter/1.5-14.2 mm wall*		20 mm Stone wool insulation 80 kg/m <sup>3</sup>	EI 240 C/U
40 mm diameter/1.5-14.2 mm wall*			
50 mm diameter/1.7-14.2 mm wall*			
60 mm diameter/1.9-14.2 mm wall*			
75 mm diameter/2.2-14.2 mm wall*			
90 mm diameter/2.5-14.2 mm wall*	300 x 300 mm		
100 mm diameter/2.7-14.2 mm wall*		30 mm Stone wool	
115 mm diameter/3-14.2 mm wall*		insulation 80 kg/m <sup>3</sup>	E 240, El 120 C/U
140 mm diameter/3.5-14.2 mm wall*			
165 mm diameter/ 3.9-14.2 mm wall*			
180 mm diameter/ 4.2-14.2 mm wall*			
200 mm diameter/ 4.6-14.2 mm wall*			
219 mm diameter/ 5.0-14.2 mm wall*			

\* Typical pipe diameters shown, see below graph for intermediate sizes





A.1.7 Double side penetration seal with metallic pipes

Services	Insulation	Classification
Mild or stainless steel pipe		
40 mm diameter/1-14.2 mm wall	20 mm thick stone, mineral wool min. 80 kg/m <sup>3</sup>	
40 mm diameter/1-14.2 mm wall*		
50 mm diameter/1.2-14.2 mm wall*		
60 mm diameter/1.4-14.2 mm wall*		
75 mm diameter/1.6-14.2 mm wall*		
90 mm diameter/1.9-14.2 mm wall*		
100 mm diameter/2.1-14.2 mm wall*		
115 mm diameter/2.4-14.2 mm wall*		EI 240 C/U
140 mm diameter/2.9-14.2 mm wall*	30-80 mm thick stone, mineral wool min. 80 kg/m <sup>3</sup>	
165 mm diameter/ 3.4-14.2 mm wall*		
180 mm diameter/ 3.6-14.2 mm wall*		
200 mm diameter/ 4.0-14.2 mm wall*		
219 mm diameter/ 4.3-14.2 mm wall*		
250 mm diameter/ 5.0-14.2 mm wall*		
300 mm diameter/ 5.9-14.2 mm wall*		
324 mm diameter/ 6.35-14.2 mm wall*		

A.1.7.1 Double side penetration seal with pipes







A.1.8.1	Double side penetration seal with metallic pipes with combustible insulation	
---------	--	--

Services	Insulation	Classification
Mild or stainless steel pipe		
22 mm diameter/2-11 mm wall	13 mm thick Elastomeric insulation minimum class B-s3,d0	E 240 C/U, EI 180 C/U
22-114 mm diameter/2-14.2 mm wall	13-25 mm thick Elastomeric insulation minimum class B-s3,d0	E 120 C/U, EI 90 C/U
22-114 mm diameter/2-14.2 mm wall	25-50 mm thick Elastomeric insulation minimum class B-s3,d0	EI 60 C/U

#### A.1.9 Double side penetration seal with plastic pipes

**Penetration Seal:** Plastic pipes (single) fitted at any position within the aperture, with 25 mm FernoCryl to both sides of the wall, backed with 25 mm deep stone wool insulation minimum 35 kg/m<sup>3</sup>. Minimum annular space 10 mm (A1) and minimum separation between penetration seals 30 mm (A2). Maximum seal size 300 x 300 mm / 300 mm Ø



Pipe material	Size	Classification
PVC-U pipe according to EN 1329-1, EN 1452-1 and EN 1453-1, PVC-C according to EN 1566-1	6-32 mm diameter/1.0-2.4 mm wall	EI 240 U/C
PP pipe according to EN 1451-1 or DIN	32 mm diameter/2.0-4.4 mm wall	EI 180 C/U
8077/8078	12-32 mm diameter/1.8-4.4 mm wall	EI 240 C/U
PE pipe according to EN 1519-1, EN 12201-2 and EN 12666-1, ABS according	20-32 mm diameter/2.0 mm wall	EI 240 C/U
to EN 1455-1 and pipes made from SAN+PVC according to EN 1565-1	20-32 mm diameter/2.0-4.4 mm wall	EI 120 C/U

# A.2 Flexible and rigid wall constructions according to 2. 2) with wall thickness of minimum 75 mm

# A.2.1 Double side penetration seal with cables

**Penetration Seal:** Cables (single or bundles up to 100 mm  $\emptyset$ ) and pipes fitted at any position within the aperture, with FernoCryl to both sides of the wall. Minimum annular space 10 mm (A1) and minimum separation between penetration seals 30 mm (A2), maximum seal size 150 x 150 mm / 344 mm diameter (when incorporating a pipe of seal diameter -20 mm).



## A.2.1.1

Services	Sealant depth	Backing	Classification	
None (blank)		Any material	EI 60	
Cables up to 21 mm Ø, single	12.5 mm		E 60, El 45	
Cables up to 21 mm $\emptyset$ , in bundles up to 100 mm $\emptyset$		None	E 45, El 30	
Mild or stainless steel pipe		-		
4 mm diameter /0.7-2.0 mm wall	12.5 mm	None	E 60 C/U, EI 45 C/U	
5-22 mm diameter /0.7-11 mm wall*	12.5 11111	None	E 60 C/U, EI 30 C/U	
Mild or stainless steel pipe with minimum 80	O kg/m <sup>3</sup> density	stone wool insula	tion Continuous Sustained (CS)	
40 mm diameter /1-14.2 mm wall, 20 mm insulation	12.5 mm	None	E 60 C/U, EI 45 C/U	
40-324 mm diameter /1.0-14.2 mm wall, 30 mm insulation*				
PVC-U pipe according to EN 1329-1, EN 1452	2-1 and EN 1453	-1, PVC-C accordi	ng to EN 1566-1	
6-32 mm Ø/1.0-1.8 mm wall, with bundle of cables up to 21 mm diameter*	12.5 mm	None	E 60 U/C, EI 45 U/C	
PP pipe according to EN 1451-1 or DIN 8077	/8078			
20 mm Ø/2.3 mm wall			EI 45 U/C	
21-32 mm Ø/2.3-4.4 mm wall*	12.5 mm	None	EI 30 U/C	
21-32 mm $\emptyset$ /2.3-4.4 mm wall, with bundle of cables up to 21 mm diameter*	12.5 11111	None	E 45 U/C, EI 30 U/C	
PE pipe according to EN 1519-1, EN 12201-2 from SAN+PVC according to EN 1565-1	and EN 12666-:	1, ABS according t	o EN 1455-1 and pipes made	
20 mm Ø/2.0 mm wall		None	EI 45 U/C	
21-32 mm Ø/2.0-3.0 mm wall*	12.5 mm		EI 30 U/C	
21-32 mm $Ø/2.0$ -3.0 mm wall, with bundle of cables up to 21 mm* diameter	12.3 11111		E 45 U/C, EI 30 U/C	

\* See below graphs for interpolated pipe sizes

Page 26 of 86 of European Technical Assessment ETA-22/0711 issued on 2023-02-15





PP Pipes - EI 30 U/C





PE Pipes - EI 30 U/C

# A.3 Flexible and rigid wall constructions according to 2.2) with wall thickness of minimum 100 mm

# A.3.1 Double side penetration seal with cables



## A.3.1.1

Services	Sealant depth	Backing	Maximum aperture	Classification
None (blank)	12.5 mm	Stone wool 20 mm deep 35-140 kg/m <sup>3</sup>		EI 120
Cables up to 21 mm $\emptyset$ , single or in bundles up to 50 mm $\emptyset$	12.5 mm	Stone wool 12.5 mm deep min. 33 kg/m <sup>3</sup>		E 120, El 90
Electrical cables up to 21 mm $Ø$ , single or in bundles up to 100 mm $Ø$	25	Stone wool 20 mm deep min. 40 kg/m <sup>3</sup>	300 x 300 mm*	EI 120
Electrical cables up to 80 mm $\phi$ , single or in bundles up to 100 mm $\phi$	25 mm	25 mm Bloem Mineral Fiber Bio Wool		E 120, El 60
Single 'E cable' - 1 x 185 mm <sup>2</sup> core HD603.3 electrical cable with PVC insulation, PVC sheath and 23-27 mm diameter	12.5 mm	Stone wool 20 mm deep min. 140 kg/m <sup>3</sup>		E 120, El 60

\* Or 30 mm wide x 3000 mm high for cables up to 21 mm Ø

Page 30 of 86 of European Technical Assessment ETA-22/0711 issued on 2023-02-15

Services	Sealant depth	Backing	Maximum Annular space	Classification
PVC-U pipe according to EN 1329-1, EN 1452-2	and EN 1453-1, PVC-	-C according t	o EN 1566-1	
Maximum diameter 40 mm, wall thickness 1.0- 1.9 mm for PVC pipes, fully or partially filled conduits with cables up to 21 mm diameter	25 mm	none	30 mm	EI 120 U/C
PE pipe according to EN 1519-1, EN 12201-2 and SAN+PVC according to EN 1565-1	d EN 12006-1, ABS a	ccording to El	N 1455-1 and	pipes made from
Maximum diameter 40 mm, wall thickness 2.0- 3.0 mm for PE pipes, fully or partially filled conduits with cables up to 21 mm diameter	25 mm	none	30 mm	EI 90 U/C
PP pipe according to EN 1852-1: 2009 or DIN 80	77/8078			
Maximum diameter 40 mm, wall thickness 1.8- 2.2 mm for PP pipes, fully or partially filled conduits with cables up to 21 mm diameter	25 mm	none	30 mm	EI 90 U/C

#### A.3.2 Double side penetration seal with metallic pipes



## A.3.2.1

Services	Sealant	Backing	Insulation	Classification
Mild or stainless steel pipe	depth	(minimum)		
22 mm diameter/3-10 mm wall	25 mm	Stone wool 25 mm deep 35 kg/m <sup>3</sup>	None	EI 120 C/C
Maximum 165 mm diameter/ wall*	12.5 mm	12.5 mm	9 mm Elastomeric insulation minimum class D-s3, d0	E 90 C/U El 45 C/U
	12.5 11111	stone wool 33 kg/m <sup>3</sup>	13 -25 mm Elastomeric insulation minimum class D-s3, d0	EI 60 C/U
40 mm diameter/1-14.2 mm wall*	12.5 mm	20 mm Stone wool 40 kg/m <sup>3</sup>		EI 120 C/C
40 mm diameter/1-14.2 mm wall*				
50 mm diameter/1.3-14.2 mm wall*			13 -19 mm	
60 mm diameter/1.6-14.2 mm wall*		25 mm	Elastomeric	
75 mm diameter/2-14.2 mm wall*		Bloem	insulation minimum	E 120 C/C
90 mm diameter/2.4-14.2 mm wall*	25 mm	Mineral	class B-s3,d0	EI 60 C/C
100 mm diameter/2.7-14.2 mm wall*		Fiber Bio		2.000,0
115 mm diameter/3.1-14.2 mm wall*		Wool		
140 mm diameter/3.8-14.2 mm wall*				
165 mm diameter/4.5-14.2 mm wall*		f :		

\* Typical pipe diameters shown, see below graph for intermediate sizes



Steel Pipes with Elastomeric Insulation - C/U

Services	Sealant	Backing	Insulation	Classification
Copper or steel pipe	depth			
12 mm diameter/1-6 mm wall			9 mm Elastomeric insulation minimum class B-s3,d0	EI 120 C/C
12-54 mm diameter/1-14.2 mm wall*	25 mm	25 mm Bloem Mineral Fiber Bio	9-13 mm Elastomeric insulation minimum class B-s3,d0	E 120 C/C, El 60 C/C
12-54 mm diameter/1-14.2 mm wall*		Wool	13-25 mm Elastomeric insulation minimum class B-s3,d0	EI 60 C/C
Alupex Composite Pipe				
16 mm diameter/ wall*			9 mm Elastomeric insulation minimum	E 120 C/C El 90 C/C
Maximum 75 mm diameter/ wall*			class D-s3, d0	E 60 C/C El 45 C/C
	12.5 mm	12.5 mm stone wool 33 kg/m <sup>3</sup>	13-24 mm Elastomeric insulation minimum class D-s3, d0	E 90 C/C El 60 C/C
			25 mm Elastomeric insulation minimum class D-s3, d0	EI 90 C/C
16 mm diameter/2.25 mm wall			9 mm Elastomeric insulation minimum class B-s3,d0	EI 120 C/C
16 mm diameter/2.25 mm wall		25 mm		
20 mm diameter/2.5 mm wall	25 mm	Bloem		
26 mm diameter/3 mm wall	23 11111	Mineral	9-25 mm	
32 mm diameter/3 mm wall		Fiber Bio	Elastomeric	EI 60 C/C
40 mm diameter/3.5 mm wall		Wool	insulation minimum	
50 mm diameter/4 mm wall			class B-s3,d0	
63 mm diameter/4.5 mm wall				
75 mm diameter/4.7 mm wall		<u></u>		



Alupex Pipes with Elastomeric Insulation - C/C 75, 4.6 Pipe Wall Thickness - mm e 16, 2.25 Pipe Diameter - mm

Copper or Steel Pipes with Elastomeric Insulation - C/C

Services	Sealant	Backing	Insulation	Classification
Mild or stainless steel pipe	depth	(minimum)		
16 mm diameter/ wall*			15 mm thick	EI 90 C/U
10 min diametery wait			phenolic insulation	EI 90 C/ U
	25 mm	Nono	25 mm thick	E 90 C/U, EI 60 C/U
Maximum 273 mm/ wall*	25 mm	None	phenolic insulation	E 90 C/U, EI 60 C/U
Waxinun 275 mm/ wan				26-100 mm thick
			phenolic insulation	



Steel Pipes with Phenolic Insulation - C/U



A.3.3 Double side penetration seal with metallic pipes
Services	Insulation	Classification
Mild or stainless steel pipe	]	
40 mm diameter/1-14.2 mm wall	20 mm thick stone, mineral wool min. 80 kg/m <sup>3</sup>	
40 mm diameter/1-14.2 mm wall*		
50 mm diameter/1.2-14.2 mm wall*		
60 mm diameter/1.4-14.2 mm wall*		
75 mm diameter/1.6-14.2 mm wall*		
90 mm diameter/1.9-14.2 mm wall*		
100 mm diameter/2.1-14.2 mm wall*		
115 mm diameter/2.4-14.2 mm wall*		E 120 C/U
140 mm diameter/2.9-14.2 mm wall*	30-80 mm thick stone, mineral wool min. 80 kg/m <sup>3</sup>	EI 90 C/U
165 mm diameter/ 3.4-14.2 mm wall*		
180 mm diameter/ 3.6-14.2 mm wall*		
200 mm diameter/ 4.0-14.2 mm wall*		
219 mm diameter/ 4.3-14.2 mm wall*		
250 mm diameter/ 5.0-14.2 mm wall*		
	4	

300 mm diameter/ 5.9-14.2 mm wall\* 324 mm diameter/ 6.35-14.2 mm wall\*





Services	Insulation	Classification
PEX pipe in pipe system		
15 mm diameter x 2.5 mm wall inner	None	EI 120 C/C
/25mm diameter outer		
Alupex pipe		
16-20 mm diameter/2.0 mm wall	None	EI 120 C/C
16-75 mm diameter/2.25-4.6 mm	20-50 mm thick glass wool or	EI 120 C/C
	stone, mineral wool min. 75	
	kg/m <sup>3</sup>	
Mild or Stainless Steel pipe		
4 mm diameter/1.0-2.0 mm wall		51.00.0/0
5-30 mm diameter/1.0-14.2 mm wall*	None	EI 90 C/C
30 mm diameter/2.0-14.2 mm wall		EI 120 C/U
Copper or Steel pipe		
6-12 mm diameter/0.7-6.0 mm wall*		E 90 C/C, EI 60 C/C
13-22 mm diameter/0.7-11 mm wall*	None	E 90 C/C, EI 30 C/C
12-54 mm diameter/0.9-14.2 mm wall*	20-80 mm thick stone, mineral wool min. 80 kg/m <sup>3</sup>	E 120 C/C, EI 60 C/C

\* See below graphs for interpolated pipe sizes





Copper or Steel Pipes with Mineral Wool Insulation - C/C



Copper or Steel Pipes - C/C

#### A.3.4 Double side penetration seal with composite pipes

**Penetration Seal:** CI (Continuous Interrupted) or CS (Continuous Sustained) insulated composite pipes (single) fitted at any position within the aperture, with FernoCryl to both sides of the wall, minimum 10 mm seal width around service, maximum seal size 300 x 300 mm, backed with stonewool.



## A.3.4.1

Services Alupex Composite Pipe	Sealant depth	Backing (minimum)	Insulation (minimum)	Classification
16 mm diameter/2.25 mm wall	ucptil	(,	()	
20 mm diameter/2.5 mm wall				
26 mm diameter/3 mm wall				
32 mm diameter/3 mm wall	12.5 mm	12.5 mm	20 mm stonewool 80 kg/m³, 500 mm	
40 mm diameter/3.5 mm wall	12.5 1111	stonewool 40 kg/m <sup>3</sup>	length from both	EI 120 C/C
50 mm diameter/4 mm wall			sides of the seal	
63 mm diameter/4.5 mm wall				
75 mm diameter/4.7 mm wall				

Double side penetration seal with metallic (and composite) pipes



#### A.3.5.1

Services	Sealant depth	Backing (minimum)	Insulation (minimum)	Classification
Ma	iximum ape	rture size 300	x 300 mm	
Copper or steel pipe up to 54 mm diameter/1-14.2 mm wall		20 mm Stone wool 40 kg/m <sup>3</sup>	500 mm length of 20 mm stone wool 80 kg/m <sup>3</sup>	EI 120 C/U
Alupex composite pipe 75 mm diameter/7.5 mm wall	12.5 mm	20 mm Stone wool 140 kg/m <sup>3</sup>	600 mm length of 25 mm Bloem Mineral Fiber Bio Wool	EI 60 C/U

Page 42 of 86 of European Technical Assessment ETA-22/0711 issued on 2023-02-15	Page 42 of 86 of European	<b>Technical Assessment</b>	ETA-22/0711	issued on 2023-02-15
---	---------------------------	-----------------------------	-------------	----------------------

Services	Sealant	Backing	Insulation	Classification
Mild or stainless steel pipe	depth	(minimum)	(minimum)	
Ma	iximum ape	rture size 300	x 300 mm	
40 mm diameter/1-14.2 mm wall			500 mm length of 20 mm stone wool 80 kg/m <sup>3</sup>	EI 120 C/U
40 mm diameter/1-14.2 mm wall*				
50 mm diameter/1.2-14.2 mm wall*				
60 mm diameter/1.4-14.2 mm wall*		20mm		
75 mm diameter/1.7-14.2 mm wall*		Stone wool 40 kg/m <sup>3</sup>	500 mm length of 30 mm stone wool 80 kg/m <sup>3</sup>	E 120 C/U, EI 90 C/U
90 mm diameter/2-14.2 mm wall*				
100 mm diameter/2.2-14.2 mm wall*				
115 mm diameter/2.5-14.2 mm wall*				
140 mm diameter/3-14.2 mm wall*				
165 mm diameter/3.5-14.2 mm wall*				
180 mm diameter/3.8-14.2 mm wall*		20mm	500 mm length of	
200 mm diameter/4.2-14.2 mm wall*	12.5 mm	Stone wool 40 kg/m <sup>3</sup>	30 mm stone wool 80 kg/m <sup>3</sup>	E 120 C/U, EI 90 C/U
219 mm diameter/4.5-14.2 mm wall*			5,	

\* Typical pipe diameters shown, see below graph for intermediate sizes



Steel Pipes with Mineral Wool Insulation - C/U

## A.3.5 Double side penetration seal with plastic pipes

**Penetration Seal:** Combustible pipes (single) fitted at any position within the aperture, with FernoCryl to both sides of the wall, Minimum annular space 10 mm and minimum separation between penetration seals 30 mm (A2).



## A.3.6.1

Pipe material	Sealant depth	Pipe size	Maximum Annular space	Classification												
PVC-U pipe according to EN		6-32 mm Ø/1.0-2.4	10 mm	EI 120 U/C												
1329-1, EN 1452-1 and EN 1453-1, PVC-C according to EN	25 mm	mm wall*		E 120 U/C, EI 90 U/C												
1566-1		6-32 mm Ø/1.0-1.6 mm wall	- 30 mm	EI 120 C/C												
		20 mm Ø/2.2 mm wall		EI 120 U/C												
PP pipe according to EN 1451-1 or DIN 8077/8078		20 mm Ø/2.2-4.4 mm wall		EI 60 U/C												
		25 mm	20-32 mm Ø/1.8-4.4 mm wall	30 mm	EI 60 C/C											
PE pipe according to EN 1519-1, EN 12201-2 and EN 12666-1,		20 mm Ø/2.0 mm wall	30 mm	EI 120 U/C												
ABS according to EN 1455-1 and pipes made from SAN+PVC according to EN 1565-1															20-32 mm Ø/2.0-3.0 mm wall	30 mm
Uponor Wirsbo PEX pipe in pipe system according to ISO 15875		Diameter up to 54 mm/0.4 mm wall thickness (outer pipe), 28 mm diameter/4.0 mm wall thickness (inner pipe)	30 mm	E 60 C/C, EI 45 C/C												

\* See below graphs for interpolated pipe sizes



PVC-U Pipes - U/C

# A.4 Flexible and rigid wall constructions according to 2.2) with wall thickness of minimum 120 mm

## A.4.1 Double side penetration seal with cables



#### A.4.1.1

Services	Sealant depth	Backing	Classification
Mild or stainless steel pipe			
30 -324 mm diameter /1.6-14.2 mm wall	15 mm	15 mm	E 120 C/U
50-524 IIIII diameter / 1.0-14.2 IIIII waii	13 11111	stone wool	E 120 C/O
Copper or steel pipe			
12 -54 mm diameter /0.9-14.2 mm wall	15 mm	15 mm	E 120 C/C
	13 11111	stone wool	E 120 C/C
Alupex Pipe			
16-75 mm diameter/2.0-4.6 mm wall	15 mm	15 mm	E 120 C/C, EI 30 C/C
	13 11111	stone wool	E 120 C/C, El 30 C/C

## A.5 Timber wall constructions with wall thickness of minimum 100 mm

## A.5.1 Double side penetration seal with cables

**Penetration Seal:** Cables fitted at any position within the aperture, sealed with FernoCryl, minimum 25 mm deep to both sides of the wall and backed with stone wool insulation (minimum 33kg/m3), minimum 25 mm deep. Minimum annular space 10 mm (a1) and minimum separation between penetration seals 0 mm (a2).



## A.5.1.1

Services	Sealant depth	Backing	Maximum aperture	Classification
None (blank)				EI 120
Cables up to 14 mm $\emptyset$ , single or in bundles up to 100 mm $\emptyset$	25 mm			EI 90
Cables up to 21 mm $\emptyset$ , single or in bundles up to 100 mm $\emptyset$		Stone wool 25 mm deep min.	Ø 180 mm	E 90, El 30
Cables up to 50 mm $Ø$ , single or in bundles up to 100 mm $Ø$		33kg/m <sup>3</sup>		E 90, El 30
Telecom cables up to 14 mm Ø, single or in bundles up to 100 mm Ø				E 90, El 60







## A.5.2.1

Services	Sealant depth	Backing	Maximum aperture	Insulation, minimum	Classification
None (blank)	depth		aperture	FernoTherm Coating,	EI 120
Cables up to 21 mm $Ø$ , single	25 mm	Stone wool 25 mm deep min.	Ø 180 mm	260-micron DFT extending 150 mm	EI 90
Cables up to 50 mm $Ø$ , single or in bundles up to 100 mm $Ø$		33kg/m <sup>3</sup>		from both sides of the seal	E 90, EI 60

### A.5.3 Double side penetration seal with metallic pipes

**Penetration Seal:** 500 mm (min.) LI (Local Interrupted) or CI (Continuous Interrupted) insulated metallic pipes and composite pipes (single) with glass wool or stone, mineral wool min. 75 kg/m<sup>3</sup>, fitted at any position within the aperture, with FernoCryl to both sides of the wall, backed with stone wool insulation (minimum 33kg/m<sup>3</sup>), minimum 25 mm deep. Minimum annular space 10 mm (a1) and minimum separation between penetration seals 0 mm (a2).



### A.5.3.1

Services	Maximum aperture	Sealant depth	Backing	Insulation, minimum	Classification	
Mild or stainless stee	Mild or stainless steel pipe					
Maximum 273 mm diameter /6.35-14.2 mm wall*	Ø 293 mm	25 mm	Stone wool 25 mm deep min. 33kg/m <sup>3</sup>	25 mm glass wool or stone, mineral wool min. 75 kg/m <sup>3</sup> , 500 mm length from both sides of the seal	E 90 C/C, EI 60 C/C	
Copper or steel pipe						
Maximum 54 mm diameter /1.2-14.2 mm wall*	Ø 180 mm	25 mm	Stone wool 25 mm deep min. 33kg/m <sup>3</sup>	20 mm glass wool or stone, mineral wool min. 75 kg/m <sup>3</sup> , 500 mm length from both sides of the seal	E 90 C/C, EI 60 C/C	
Alupex Pipe						
Maximum 75 mm diameter/wall 2.25- 4.6 mm wall*	Ø 180 mm	25 mm	Stone wool 25 mm deep min. 33kg/m <sup>3</sup>	25 mm glass wool or stone, mineral wool min. 75 kg/m <sup>3</sup> , 500 mm length from both sides of the seal	EI 90 C/C	

\* Typical pipe diameters shown, see below graph for intermediate sizes



Steel Pipes with Glass Wool or Mineral Wool Insulation -

C/C



Copper or Steel Pipes with Glass Wool or Mineral Wool Insulation - C/C











### A.5.4.1

Services	Sealant depth	Backing	Insulation, minimum	Classification		
Mild or stainless steel pipe						
Maximum 114 mm diameter /1.5-14.2 mm wall*	25 mm	Stone wool 25 mm deep min. 33kg/m <sup>3</sup>	9-25 mm Elastomeric insulation minimum class D-s3, d0	EI 30 C/U		
Copper or steel pipe						
Maximum 12 mm diameter /0.7-6 mm wall*			9 mm Elastomeric	E 90 C/C, EI 60 C/C		
Maximum 54 mm diameter /1.2-14.2 mm wall*	25 mm	25 mm	25 mm	Stone wool 25 mm deep min.	insulation minimum class D-s3, d0	E 60 C/C, EI 30 C/C
Maximum 54 mm diameter /1.2-14.2 mm wall*		33kg/m <sup>3</sup>	10-25 mm Elastomeric insulation minimum class D-s3, d0	E 30 C/C, EI 20 C/C		
Alupex Pipe						
Maximum 16 mm diameter/wall 2.25 mm wall*		Stone wool 25 mm deep min. 33kg/m <sup>3</sup>	9 mm Elastomeric insulation minimum	EI 90 C/C		
Maximum 75 mm diameter/wall 4.6 mm wall*	25 mm		class D-s3, d0	E 60 C/C, EI 45 C/C		
Maximum 75 mm diameter/wall 4.6 mm wall*	23 11111		10-25 mm Elastomeric insulation minimum class D-s3, d0	EI 45 C/C		

\* Typical pipe diameters shown, see below graph for intermediate sizes





Copper or Steel Pipes with Elastomeric Insulation - C/C







**Penetration Seal:** Plastic and composite pipes (single) fitted at any position within the aperture, with FernoCryl to both sides of the wall, backed with stone, mineral wool min. 33 kg/m<sup>3</sup>. Minimum annular space 10 mm and maximum 30 mm (a1) and minimum separation between penetration seals 0 mm (a2).



## A.5.5.1

Services	Sealant depth	Backing	Classification		
PVC-U pipe according to EN 1329-1, EN 1452-1	and EN 1453-1,	PVC-C according to EN 156	6-1		
Maximum 32 mm diameter/1.0-2.4 mm wall*	laximum 32 mm diameter/1.0-2.4 mm wall* 25 mm deep min. 33kg/m <sup>3</sup>		EI 90 U/C		
PE pipe according to EN 1519-1, EN 12201-2 and SAN+PVC according to EN 1565-1	PE pipe according to EN 1519-1, EN 12201-2 and EN 12666-1, ABS according to EN 1455-1 and pipes made from SAN+PVC according to EN 1565-1				
Maximum 32 mm diameter/2.0-3.0 mm wall*	25 mm	Stone wool 25 mm deep min. 33kg/m <sup>3</sup>	EI 90 U/C		
PP pipe according to EN 1451-1 or DIN 8077/80	78				
Maximum 32 mm diameter/1.8-4.4 mm wall*	25 mm	Stone wool 25 mm deep min. 33kg/m <sup>3</sup>	EI 90 U/C		
PEX pipe in pipe system					
25 mm diameter outer /15 mm diameter x 2.5 mm wall inner	25 mm	Stone wool 25 mm deep min. 33kg/m <sup>3</sup>	EI 90 C/C		

\* Typical pipe diameters shown, see below graph for intermediate sizes



PVC-U Pipes El 90 - U/C



PE Pipes El 90 - U/C



## A.6 Rigid floor constructions according to 1.2.1 with floor thickness of minimum 150 mm

## A.6.1 Single side penetration seal with cables

**Penetration Seal:** Cables (single) fitted at any position within the aperture, min. 10 mm from the edges, with FernoCryl to either side of the floor (or at any position in between), backed with 'Bloem Mineral Fiber Bio Wool'.



## A.6.1.1

Services	Sealant depth	Backing (minimum)	Aperture (maximum)	Classification
Single electrical cables up to 21 mm Ø	25 mm	Bloem Mineral Fiber Bio Wool 25mm deep	82 mm Ø or 100 x 1000 mm	E 120, El 60

## A.6.2 Single side penetration seal with cables



## A.6.2.1

Services	Sealant depth	Backing (minimum)	Insulation	Classification
	15 mm	20 mm Stone wool 35 kg/m <sup>3</sup>		E 90, El 60
Blank seals	25 mm	25 mm Stone wool 35 kg/m <sup>3</sup>	None	EI 120
Electric cables up to 21 mm diameter, single.		48 mm Mineral	None	El 240 E 120, El 90
23-27 mm diameter, 1 mm × 185 mm <sup>2</sup> core, PVC sheath and insulation electrical cable, single		Fibre BIO		EI 240

### A.6.3 Single side penetration seal with pipes



#### A.6.3.1

Services	Sealant depth	Backing	Classification
Mild or stainless steel pipe			
4 -16 mm diameter /1.0-8.0 mm wall	25 mm	48 mm	EI 120 C/U
17 -324 mm diameter /1.0-14.2 mm wall	25 mm	stone wool	E 120 C/U
Copper or steel pipe			
6 mm diameter /0.7-3.0 mm wall		40	EI 120 C/C
6 -15 mm diameter /0.7-7.5 mm wall	25 mm	48 mm	E 120 C/C, EI 60 C/C
16 - 54 mm diameter /0.7-14.2mm wall		stone wool	E 120 C/C
Copper or steel pipe with minimum 80 kg/m <sup>3</sup> density stone wo	ol insulatio	n Continuous Su	ustained (CS)
12 mm diameter/0.9-6 mm wall, 20-80 mm insulation	25	48 mm	EI 240 C/C
13-54 mm diameter/0.9-14.2 mm wall, 20-80 mm insulation*	25 mm	stone wool	E 240 C/C, EI 180 C/C
Alupex Pipe			
16 -20 mm diameter/2.0 mm wall	25		EI 120 C/C
21-75 mm diameter/2.0-4.6 mm wall	25 mm	48 mm	E 120 C/C, EI 90 C/C
16-75 mm diameter/2.25-4.6 mm wall with 20-50 mm thick glass wool or stone, mineral wool min. 75 kg/m <sup>3</sup> insulation	25 mm	stone wool	E 180 C/C, EI 120 C/C
Continuous Sustained (CS)			

\*See below graphs for interpolated pipe sizes



Copper or Steel Pipes with 20-80 mm stone wool Insulation CS E 240 C/C, EI 180 C

#### A.6.4 Double side penetration seal with pipes



## A.6.4.1

Services	Sealant depth	Backing	Classification			
PVC-U pipe according to EN 1329-1, EN 1452-1 and EN 1453-1, PVC-C according to EN 1566-1						
Up to 50 mm Ø/1.6-3.7 mm wall						
Up to 40 mm $\emptyset$ /1.6-3.7 mm wall, with	25 mm	25 mm Stone	EI 240 U/C			
bundle of cables up to 21 mm	25 11111	wool	EI 240 0/C			
diameter						
PP pipe according to EN 1451-1 or DIN 8077/8078						
12 mm Ø/1.2 mm wall			EI 240 U/C			
13-75 mm Ø/1.2-6.8 mm wall*	25 mm	25 mm Stone	EI 90 U/C			
Up to 40 mm $Ø/1.2$ -1.8 mm wall, with		wool				
bundle of cables up to 21 mm		WOOI	EI 180 U/C			
diameter						
PE pipe according to EN 1519-1, EN 1220	1-2 and EN 12666-	1, ABS according t	o EN 1455-1 and pipes made			
from SAN+PVC according to EN 1565-1						
20-40 mm Ø/2.0-2.4 mm wall*		25 mm 25 mm Stone - wool	EI 240 U/C			
Up to 40 mm $Ø/2.0$ -2.4 mm wall, with	25 mm					
bundle of cables up to 21 mm			EI 180 U/C			
diameter						

\*See below graphs for interpolated pipe sizes











**Penetration Seal:** Cables fitted circular apertures or min. 7 mm from the edges of rectilinear apertures, with FernoCryl to both sides of the floor, backed with stone wool insulation minimum 35kg/m<sup>3</sup>.



#### A.6.5.1

Services	Sealant depth	Backing	Maximum Aperture	Classification
Blank seals				EI 240
Electric cables up to 21 mm diameter, single or in a bundle.		25 mm	200 200	El 120
Electric cables 22-50 mm diameter, single or in a bundle.	15 mm	Stone wool 35 kg/m <sup>3</sup>	300 x 300 mm	E 120, El 90
Electric cables 51-80 mm diameter, single or in a bundle.				E 120, El 60



**Penetration Seal:** 1000 mm (min.) LI (Local Interrupted) or CI (Continuous Interrupted) insulated metallic pipes (single) fitted at any position within the aperture, with 15 or 25 mm deep FernoCryl to either side of the floor (or at any position between), backed with minimum 40 kg/m<sup>3</sup> stone wool insulation or Bloem Mineral Fiber Bio Wool.



#### A.6.6.1

Services	Max. seal size	Insulation (min)	Sealant depth	Classification				
Copper or steel pipe up to 54 mm diameter/0.9-14.2 mm wall	10 mm width around pipe			E 240 C/U, EI 180 C/U				
Copper or steel pipe up to 12 mm diameter/0.9-5 mm wall		20 mm Stone wool insulation 80 kg/m <sup>3</sup>	15 mm	EI 240 C/U				
Copper or steel pipe up to 54 mm diameter/0.9-14.2 mm wall	Up to 100 x 1000 mm		25 mm	EI 120 C/U				
Copper or steel pipe up to 54 mm diameter/0.9-14.2 mm wall		20 mm	15 mm	E 90 C/U, EI 60 C/U				
Copper or steel pipe up to 12 mm diameter/0.9-5 mm wall	300 x 300 mm					Stone wool insulation	13 11111	
Copper or steel pipe up to 54 mm diameter/0.9-14.2 mm wall		80 kg/m <sup>3</sup>	25 mm	EI 120 C/U				

Services	Max. Seal Size	Insulation	Sealant	Classification
Mild or stainless steel pipe		(min)	Depth	
40 mm diameter/1-14.2 mm wall		20 mm Stone wool insulation 80 kg/m <sup>3</sup>		EI 240 C/U
40 mm diameter/1-14.2 mm wall*				
50 mm diameter/1.2-14.2 mm wall*				
60 mm diameter/1.4-14.2 mm wall*				
75 mm diameter/1.7-14.2 mm wall*				
90 mm diameter/2-14.2 mm wall*	10 mm width		15 mm	
100 mm diameter/2.2-14.2 mm wall*	around pipe	30 mm Stone wool		
115 mm diameter/2.5-14.2 mm wall*		insulation 80		E 240 C/U, EI 90 C/U
140 mm diameter/3-14.2 mm wall*		kg/m <sup>3</sup>		
165 mm diameter/3.5-14.2 mm wall*				
180 mm diameter/3.8-14.2 mm wall*				
200 mm diameter/4.2-14.2 mm wall*				
219 mm diameter/4.5-14.2 mm wall*				
40 mm diameter/1-14.2 mm wall*		20 mm Stone wool insulation 80 kg/m <sup>3</sup>		
50 mm diameter/1.2-14.2 mm wall*		_		
60 mm diameter/1.4-14.2 mm wall*				
75 mm diameter/1.7-14.2 mm wall*				
90 mm diameter/2-14.2 mm wall*	Up to 100 x			
100 mm diameter/2.2-14.2 mm wall*	1000 mm	30 mm Stone	25 mm	E120 C/U, EI 90 C/U
115 mm diameter/2.5-14.2 mm wall*		wool insulation 80		
140 mm diameter/3-14.2 mm wall*		kg/m <sup>3</sup>		
165 mm diameter/3.5-14.2 mm wall*				
180 mm diameter/3.8-14.2 mm wall*				
200 mm diameter/4.2-14.2 mm wall*	]			
219 mm diameter/4.5-14.2 mm wall*				

\* Typical pipe diameters shown, see below graph for intermediate sizes

Services	Max. Seal Size	Insulation	Sealant	Classification
Mild or stainless steel pipe		(minimum)	Depth	
40 mm diameter/1-14.2 mm wall		20 mm Stone wool insulation 80 kg/m <sup>3</sup>		
40 mm diameter/1-14.2 mm wall*				
50 mm diameter/1.2-14.2 mm wall*				
60 mm diameter/1.4-14.2 mm wall*				
75 mm diameter/1.7-14.2 mm wall*				
90 mm diameter/2-14.2 mm wall*			15 mm	E 90 C/U, EI 60 C/U
100 mm diameter/2.2-14.2 mm wall*		30 mm Stone wool		
115 mm diameter/2.5-14.2 mm wall*		insulation 80		
140 mm diameter/3-14.2 mm wall*	-	kg/m <sup>3</sup>		
165 mm diameter/3.5-14.2 mm wall*				
180 mm diameter/3.8-14.2 mm wall*				
200 mm diameter/4.2-14.2 mm wall*				
219 mm diameter/4.5-14.2 mm wall*	300 x 300 mm			
40 mm diameter/1-14.2 mm wall*		20 mm Stone wool insulation 80 kg/m <sup>3</sup>		
50 mm diameter/1.2-14.2 mm wall*				
60 mm diameter/1.4-14.2 mm wall*				
75 mm diameter/1.7-14.2 mm wall*				
90 mm diameter/2-14.2 mm wall*				
100 mm diameter/2.2-14.2 mm wall*		30 mm Stone	25 mm	E120 C/U, EI 90 C/U
115 mm diameter/2.5-14.2 mm wall*		wool insulation 80		
140 mm diameter/3-14.2 mm wall*		kg/m <sup>3</sup>		
165 mm diameter/3.5-14.2 mm wall*				
180 mm diameter/3.8-14.2 mm wall*				
200 mm diameter/4.2-14.2 mm wall*				
219 mm diameter/4.5-14.2 mm wall*				

\* Typical pipe diameters shown, see below graph for intermediate sizes



Steel Pipes with Stone Wool Insulation - C/U





A.6.7.1	Single side	penetration	seal with pipes
---------	-------------	-------------	-----------------

Services	Insulation	Classification				
Mild or stainless steel pipe						
40 mm diameter/1-14.2 mm wall	20 mm thick stone, mineral					
	wool min. 80 kg/m <sup>3</sup>					
40 mm diameter/1-14.2 mm wall*						
50 mm diameter/1.2-14.2 mm wall*						
60 mm diameter/1.4-14.2 mm wall*						
75 mm diameter/1.6-14.2 mm wall*						
90 mm diameter/1.9-14.2 mm wall*						
100 mm diameter/2.1-14.2 mm wall*	30-80 mm thick stone, mineral wool min. 80 kg/m <sup>3</sup>					
115 mm diameter/2.4-14.2 mm wall*		EI 240 C/U				
140 mm diameter/2.9-14.2 mm wall*						
165 mm diameter/ 3.4-14.2 mm wall*						
180 mm diameter/ 3.6-14.2 mm wall*						
200 mm diameter/ 4.0-14.2 mm wall*						
219 mm diameter/ 4.3-14.2 mm wall*						
250 mm diameter/ 5.0-14.2 mm wall*						
300 mm diameter/ 5.9-14.2 mm wall*						
324 mm diameter/ 6.35-14.2 mm wall*						
PEX pipe in pipe system	PEX pipe in pipe system					
15 mm diameter x 2.5 mm wall inner	None	EI 90 C/C				
/25mm diameter outer						



#### Steel Pipes with Mineral Wool Insulation - C/U

## A.6.8 Single side penetration seal with composite pipes



## A.6.8.1

Services Alupex Composite Pipe	Sealant depth	Backing	Insulation (minimums)	Classification
16 mm diameter/2.25 mm wall				
20 mm diameter/2.5 mm wall				
26 mm diameter/3 mm wall		48 mm		
32 mm diameter/3 mm wall	25 mm	Bloem	20 mm stonewool 80 kg/m <sup>3</sup> , 500 mm	
40 mm diameter/3.5 mm wall	25 11111	Mineral Fiber Bio	length from both	EI 240 C/C
50 mm diameter/4 mm wall		Wool	sides of the seal	
63 mm diameter/4.5 mm wall				
75 mm diameter/4.7 mm wall				

A.6.9 Double side penetration seal with metallic pipes Penetration Seal: Non-insulated metallic pipes (single) fitted at any position within the aperture, with FernoCryl to both sides of the floor, backed with stone wool or mineral fibre insulation. Construction details: PIPE -ACRYLIC CONCRETE FLOOR MINERAL FIBRE · . 150 MINERAL FIBRE ACRYLIC APERTURE

## A.6.9.1

Services	Max. Seal Size	Insulation	Sealant depth	Backing (minimum)	Classification
Copper or steel pipe 54 mm diameter/2-14.2 mm wall	300 x 300 mm	None	25 mm	25 mm deep 140 kg/m <sup>3</sup> stone wool	E 120 C/U, El 20 C/U
Mild steel pipe 16 mm diameter/1.5-7.5 mm wall			25 mm		EI 240 C/U
Mild steel pipe maximum 63 mm diameter/1.5-14.2 mm wall			15 mm	25 mm deep 35 kg/m <sup>3</sup> stone wool	E 240 C/U EI 30 C/U
Mild steel pipe 16 mm diameter/1.5-7.5 mm wall	Up to 100 x 1000 mm		25 mm	Bloem Mineral Fiber Bio Wool 25 mm deep	EI 120 C/U




#### A.6.10.1

Services	Sealant	Backing	Insulation	Classification
Mild or stainless steel pipe	depth	(minimum)		
40 mm diameter/1-14.2 mm wall		20 mm		
	25 mm	Stone wool		EI 180 C/U
		40 kg/m <sup>3</sup>		
40 mm diameter/1-14.2 mm wall*				
50 mm diameter/1.3-14.2 mm wall*			13 -19 mm	
60 mm diameter/1.6-14.2 mm wall*			Elastomeric	
75 mm diameter/2-14.2 mm wall*		25 mm Bloem	insulation minimum class B-s3,d0 or	
90 mm diameter/2.4-14.2 mm wall*	25 mm	Mineral	phenolic foam	EI 60 C/U
100 mm diameter/2.7-14.2 mm wall*		Fiber Bio Wool	insulation	
115 mm diameter/3.1-14.2 mm wall*				
140 mm diameter/3.8-14.2 mm wall*				
165 mm diameter/4.5-14.2 mm wall*				

\* Typical pipe diameters shown, see below graph for intermediate sizes



## Steel Pipes with 13-19 mm Elastomeric Insulation - C/U

Page 74 of 86 of European	Technical Assessment ETA-22/0711	issued on 2023-02-15
---------------------------	----------------------------------	----------------------

Services	Sealant	Backing	Insulation	Classification
Copper or steel pipe	depth	(minimum)		
12 mm diameter/1-6 mm wall			9 mm Elastomeric	
			insulation minimum	
			class B-s3,d0 or	E 240 C/C, EI 180 C/C
			phenolic foam	
			insulation	
12-54 mm diameter/1-14.2 mm wall*			9-13 mm	
		25 mm	Elastomeric	
		Bloem	insulation minimum	E 180 C/C, EI 120 C/C
	25 mm	Mineral	class B-s3,d0 or	L 100 C/ C, LI 120 C/ C
		Fiber Bio	phenolic foam	
		Wool	insulation	
12-54 mm diameter/1-14.2 mm wall*			13-25 mm	
			Elastomeric	
			insulation minimum	E 90 C/C, EI 60 C/C
			class B-s3,d0 or	
			phenolic foam	
			insulation	

\* Typical pipe diameters shown, see below graph for intermediate sizes



Copper or Steel Pipes with Elastomeric Insulation - C/C

Services	Sealant	Backing	Insulation	Classification
Alupex Composite Pipe	depth	(minimum)		
16 mm diameter/2.25 mm wall			9 mm Elastomeric insulation minimum class B-s3,d0 or phenolic foam insulation	EI 180 C/C
16 mm diameter/2.25 mm wall				
20 mm diameter/2.5 mm wall	_			
26 mm diameter/3 mm wall			9-13 mm	
32 mm diameter/3 mm wall			Elastomeric insulation minimum	
40 mm diameter/3.5 mm wall			class B-s3,d0 or	E 120 C/C, EI 60 C/C
50 mm diameter/4 mm wall		25 mm Bloem	phenolic foam insulation	
63 mm diameter/4.5 mm wall	25 mm	Mineral		
75 mm diameter/4.7 mm wall		Fiber Bio Wool		
16 mm diameter/2.25 mm wall				
20 mm diameter/2.5 mm wall				
26 mm diameter/3 mm wall			13-25 mm	
32 mm diameter/3 mm wall			Elastomeric insulation minimum	
40 mm diameter/3.5 mm wall			class B-s3,d0 or	EI 60 C/C
50 mm diameter/4 mm wall			phenolic foam insulation	
63 mm diameter/4.5 mm wall				
75 mm diameter/4.7 mm wall	1			





## A.6.11.1

Services	Maximum seal	Insulation	Classification
Mild or stainless steel pipe	size	(minimum)	
40 mm diameter/1-14.2 mm wall		20 mm Stone wool insulation 80 kg/m <sup>3</sup>	EI 240 C/U
40 mm diameter/1-14.2 mm wall*			
50 mm diameter/1.2-14.2 mm wall*			
60 mm diameter/1.4-14.2 mm wall*			
75 mm diameter/1.7-14.2 mm wall*			
90 mm diameter/2-14.2 mm wall*			
100 mm diameter/2.2-14.2 mm wall*	300 x 300 mm or 100 x 1000 mm	30 mm Stone wool	E 240 C/U, EI 120
115 mm diameter/2.5-14.2 mm wall*		insulation 80 kg/m <sup>3</sup>	C/U
140 mm diameter/3-14.2 mm wall*			
165 mm diameter/3.5-14.2 mm wall*			
180 mm diameter/3.8-14.2 mm wall*			
200 mm diameter/4.2-14.2 mm wall*			
219 mm diameter/4.5-14.2 mm wall*			

\* Typical pipe diameters shown, see below graph for intermediate sizes



Steel Pipes with Stone Wool Insulation - C/U

## A.7 Timber floor constructions with floor thickness of minimum 150 mm

## A.7.1 Double sided penetration seal with cables

**Penetration Seal:** Cables fitted at any position within the aperture, sealed with FernoCryl, minimum 25 mm deep to both sides of the floor and backed with stone wool insulation (minimum 33kg/m3), minimum 25 mm deep. Minimum annular space 10 mm (a1) and minimum separation between penetration seals 0 mm (a2).



Page 79 of 86 of European Technical Assessment ETA-22/0711 issued on 2023-02-15

Services	Sealant depth	Backing	Maximum aperture	Insulation, minimum	Classification
None (blank)				None	EI 120
Cables up to 14 mm $Ø$ , single or in bundles up to 100 mm $Ø$					EI 120
Cables up to 21 mm $Ø$ , single or in bundles up to 100 mm $Ø$	25 mm	Stone wool 25 mm deep min. 33kg/m <sup>3</sup>	Ø 220 mm	FernoTherm Coating, 260-micron DFT	E 120, El 90
Cables up to 50 mm $Ø$ , single or in bundles up to 100 mm $Ø$				extending 150 mm from top side of the seal	E 120, El 90
Telecom cables up to 14 mm $\emptyset$ , single or in bundles up to 100 mm $\emptyset$					E 120, El 90

### A.7.2 Double side penetration seal with metallic pipes

**Penetration Seal:** 500 mm (min.) LI (Local Interrupted) or CI (Continuous Interrupted) insulated metallic pipes and composite pipes (single) with glass wool or stone, mineral wool min. 75 kg/m<sup>3</sup>, fitted at any position within the aperture, with FernoCryl to both sides of the floor, backed with stone wool insulation (minimum 33kg/m<sup>3</sup>), minimum 25 mm deep. Minimum annular space 10 mm (a1) and minimum separation between penetration seals 0 mm (a2).



#### A.7.2.1

Services	Maximum aperture	Sealant depth	Backing	Insulation, minimum	Classification	
Mild or stainless steel	Mild or stainless steel pipe					
Maximum 273 mm diameter /6.35-14.2 mm wall*	Ø 293 mm	25 mm	Stone wool 25 mm deep min. 33kg/m <sup>3</sup>	25 mm glass wool or stone, mineral wool min. 75 kg/m <sup>3</sup> , 500 mm length from both sides of the seal	E 120 C/C, El 60 C/C	
Copper or steel pipe						
Maximum 15 mm diameter /0.7-7.5 mm wall*	<i>d</i> 220 mm	25	Stone wool	stone mineral wool min	20 mm glass wool or stone, mineral wool min.	EI 120 C/C
Maximum 54 mm diameter /1.2-14.2 mm wall*	Ø 220 mm	25 mm	25 mm deep min. 33kg/m <sup>3</sup>	75 kg/m <sup>3</sup> , 500 mm length from both sides of the seal	E 120 C/C, EI 90 C/C	
Alupex Pipe						
Maximum 16 mm diameter/ 2.25 mm wall*	<i>d</i> 220 mm	25 mm	Stone wool	20 mm glass wool or stone, mineral wool min. 75 kg/m <sup>3</sup> , 500 mm length from both sides of the seal	EI 120 C/C	
Maximum 75 mm diameter/ 4.6 mm wall*	Ø 220 mm	25 mm	25 mm deep min. 33kg/m <sup>3</sup>	25 mm glass wool or stone, mineral wool min. 75 kg/m <sup>3</sup> , 500 mm length from both sides of the seal	E 120 C/C, El 90 C/C	

\* Typical pipe diameters shown, see below graph for intermediate sizes



Steel Pipes with Glass Wool or Mineral Wool Insulation -



Copper or Steel Pipes with Glass Wool or Mineral Wool Insulation - C/C





### A.7.3 Double side penetration seal with plastic pipes and composite pipes

**Penetration Seal:** Plastic and composite pipes (single) fitted at any position within the aperture, with FernoCryl to both sides of the floor, backed with stone, mineral wool min. 33 kg/m<sup>3</sup>. Minimum annular space 10 mm and maximum 30 mm (a1) and minimum separation between penetration seals 0 mm (a2).



Page 84 of 86 of European Technical Assessment ETA-22/0711 issued on 2023-02-15

Services	Sealant depth	Backing	Classification			
PVC-U pipe according to EN 1329-1, EN 1452-1 and EN 1453-1, PVC-C according to EN 1566-1						
Maximum 32 mm diameter/1.0-2.4 mm wall*	25 mm	Stone wool 25 mm deep min. 33kg/m <sup>3</sup>	EI 120 U/C			
PE pipe according to EN 1519-1, EN 12201-2 and	d EN 12666-1, A	BS according to EN 1455-1	and pipes made from			
SAN+PVC according to EN 1565-1						
Maximum 32 mm diameter/2.0-3.0 mm wall*	25 mm	Stone wool 25 mm deep min. 33kg/m <sup>3</sup>	EI 120 U/C			
PP pipe according to EN 1451-1 or DIN 8077/80	78					
Maximum 32 mm diameter/1.8-4.4 mm wall*	25 mm	Stone wool 25 mm deep min. 33kg/m <sup>3</sup>	EI 120 U/C			
PEX pipe in pipe system						
25 mm diameter outer /15 mm diameter x 2.5 mm wall inner	25 mm	Stone wool 25 mm deep min. 33kg/m <sup>3</sup>	EI 120 C/C			

\* Typical pipe diameters shown, see below graph for intermediate sizes



PVC-U Pipes EI 120 - U/C



PE Pipes El 120 - U/C





# ANNEX B – Air Permeability – FernoCryl

Product tested	10mm deep x 30mm wide FernoCryl				
Sui	mmary of testing procedu	Result			
	Pressure (Pa)	Leakage (m <sup>3</sup> /h)	Leakage (m <sup>3</sup> /m <sup>2</sup> /h)		
	25	0.00	0.00		
	50	0.00	0.00		
Describer on description	100	0.00	0.00		
Results under negative chamber pressure	200	0.00	0.00		
	300	0.02	0.56		
	450	0.06	1.67		
	600	0.22	6.11		
	25	0.00	0.00		
	50	0.00	0.00		
De sulta un den ma siti un	100	0.00	0.00		
Results under positive chamber pressure	200	0.00	0.00		
	300	0.00	0.00		
	450	0.04	1.11		
	600	0.25	6.94		

